

UNOFFICIAL COPY



00697452

5893/0029 07 001 Page 1 of 1  
2000-09-08 10:01:32  
Cook County Recorder 23.50

VILLAGE OF LEMONT  
418 Main Street  
Lemont, Illinois 60439

CERTIFICATE OF COMPLIANCE

DATE OF INSPECTION: October 21, 1999

TYPE OF INSPECTION: Water/Sewer Violation Correction

PLUMBING INSPECTOR: Martin Haidacher

OWNER: Jim Smith

ADDRESS: 419 Glenys Drive P.I.N. 22-29-416-045

FIRM RESPONSIBLE FOR CORRECTION: Hoppy's Landscaping/Affordable Plumbing

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation:  YES  NO

Materials in compliance with 77 Ill. Adm. Code 890.Table D  YES  NO

Water and Sewer Separation: 13 Feet

COMMENTS: The separation violation at the above listed address has been corrected and is in full compliance.

Martin Haidacher  
Signature of Plumbing Inspector

Prepared by and Return to:  
Village of Lemont  
Building Department  
418 Main Street  
Lemont, Illinois 60439  
(630) 257-1580

5-7  
P-1  
5-  
my  
JHC