

# UNOFFICIAL COPY

00697470

5893/0047 07 001 Page 1 of 1  
2000-09-08 10:04:41  
Cook County Recorder 23.50

VILLAGE OF LEMONT  
418 Main Street  
Lemont, Illinois 60439



## CERTIFICATE OF COMPLIANCE

DATE OF INSPECTION: October 12, 1998

TYPE OF INSPECTION: Water/Sewer Violation Correction

PLUMBING INSPECTOR: Patrick M. Dermott

OWNER: Tom Barrett

ADDRESS: 720 Harasek Street P.I.N. 22-28-108-010


FIRM RESPONSIBLE FOR CORRECTION: Baish Excavating/C.R. Leonard Plumbing

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation:  YES  NO

Materials in compliance with 77 Ill. Adm. Code 890. Table D  YES  NO

Water and Sewer Separation: 11 Feet

COMMENTS: The separation violation at the above listed address has been corrected and is in full compliance.

  
Signature of Plumbing Inspector

Prepared by and Return to:  
Village of Lemont  
Building Department  
418 Main Street  
Lemont, Illinois 60439  
(630) 257-1580

5-7  
P1  
5-  
M-7  
8/11