

UNOFFICIAL COPY

00697497

5893/0074 07 001 Page 1 of 1
2000-09-08 10:10:01
Cook County Recorder 23.50

VILLAGE OF LEMONT
418 Main Street
Lemont, Illinois 60439



CERTIFICATE OF COMPLIANCE

DATE OF INSPECTION: May 20, 1999

TYPE OF INSPECTION: Water/Sewer Violation Correction

PLUMBING INSPECTOR: Martin Haidacher

OWNER: Richard Bitter

ADDRESS: 83 W. Logan Street P.I.N. 22-30-206-033

FIRM RESPONSIBLE FOR CORRECTION: Baish Excavating Inc./C.R. Leonard Plumbing

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation: YES NO

Materials in compliance with 77 Ill. Adm. Code 890.Table D YES NO

Water and Sewer Separation: 11 Feet 3 Inches

COMMENTS: The separation violation at the above listed address has been corrected and is in full compliance.


Signature of Plumbing Inspector

Prepared by and Return to:
Village of Lemont
Building Department
418 Main Street
Lemont, Illinois 60439
(630) 257-1580

5-7
P-1
5-
M-7
8/11c