

UNOFFICIAL COPY 00697499

5893/0076 07 001 Page 1 of 1  
2000-09-08 10:10:44  
Cook County Recorder 23.50

VILLAGE OF LEMONT  
418 Main Street  
Lemont, Illinois 60439



**CERTIFICATE OF COMPLIANCE**

DATE OF INSPECTION: June 29, 1999

TYPE OF INSPECTION: Water/Sewer Violation Correction

PLUMBING INSPECTOR: Patrick McDermott

OWNER: William Martinez

ADDRESS: 16102 New Avenue P.I.N. 22-19-401-014


FIRM RESPONSIBLE FOR CORRECTION: Hoppy's Landscaping/Affordable Plumbing

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation:  YES  NO

Materials in compliance with 77 Ill. Adm. Code 890. Table D  YES  NO

Water and Sewer Separation: Exceeds 10 Foot minimum requirement

COMMENTS: The separation violation at the above listed address has been corrected and is in full compliance.

  
Signature of Plumbing Inspector

Prepared by and Return to:  
Village of Lemont  
Building Department  
418 Main Street  
Lemont, Illinois 60439  
(630) 257-1580

5-7  
P1  
5-  
M-y  
JHK