

# UNOFFICIAL COPY

00697502

5893/0079 07 001 Page 1 of 1  
2000-09-08 10:11:15  
Cook County Recorder 23.50

VILLAGE OF LEMONT  
418 Main Street  
Lemont, Illinois 60439



00697502

## CERTIFICATE OF COMPLIANCE

DATE OF INSPECTION: June 2, 1999

TYPE OF INSPECTION: Water/Sewer Violation Correction

PLUMBING INSPECTOR: Patrick McDermott

OWNER: Laurie Saulys

ADDRESS: 54 W. Peiffer Street P.I.N. 22-30-405-008


FIRM RESPONSIBLE FOR CORRECTION: Baish Excavating/C.R. Leonard Plumbing

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation:  YES  NO

Materials in compliance with 77 Ill. Adm. Code 890. Table D  YES  NO

Water and Sewer Separation: Exceeds 13 Feet

COMMENTS: The separation violation at the above listed address has been corrected and is in full compliance.

  
Signature of Plumbing Inspector

Prepared by and Return to:  
Village of Lemont  
Building Department  
418 Main Street  
Lemont, Illinois 60439  
(630) 257-1580

5-9  
P1  
5-  
m-7  
8/14