

VILLAGE OF LEMONT
418 Main Street
Lemont, Illinois 60439



00697515

CERTIFICATE OF COMPLIANCE

DATE OF INSPECTION: November 19, 1998

TYPE OF INSPECTION: Water/Sewer Violation Correction

PLUMBING INSPECTOR: Patrick M. Dermott

OWNER: Andrew Bosko

ADDRESS: 7 Spruce Court P.I.N. 22-30-207-032

FIRM RESPONSIBLE FOR CORRECTION: Baish Excavating/C.R. Leonard Plumbing

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation: YES NO

Materials in compliance with 77 Ill. Adm. Code 890. Table D YES NO

Water and Sewer Separation: 14 Feet

COMMENTS: The separation violation at the above listed address has been corrected and is in full compliance.

Signature of Plumbing Inspector

Prepared by and Return to:
Village of Lemont
Building Department
418 Main Street
Lemont, Illinois 60439
(630) 257-1580

4-7
P1
5
M-7
JHc