

UNOFFICIAL COPY 00697516

5893/0093 07 001 Page 1 of 1  
2000-09-08 10:13:45  
Cook County Recorder 23.50

VILLAGE OF LEMONT  
418 Main Street  
Lemont, Illinois 60439



00697516

**CERTIFICATE OF COMPLIANCE**

DATE OF INSPECTION: February 23, 1999

TYPE OF INSPECTION: Water/Sewer Violation Correction

PLUMBING INSPECTOR: Patrick M. Dermott

OWNER: John Wazowicz

ADDRESS: 11 Spruce Court P.I.N. 22-60-207-028

FIRM RESPONSIBLE FOR CORRECTION: E.T. Mansell & L Plumbing

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation:  YES  NO

Materials in compliance with 77 Ill. Adm. Code 890. Table D  YES  NO

Water and Sewer Separation: Exceeds 10 ft. minimum requirement

COMMENTS: The separation violation at the above listed address has been corrected and is in full compliance.

Signature of Plumbing Inspector

Prepared by and Return to:  
Village of Lemont  
Building Department  
418 Main Street  
Lemont, Illinois 60439  
(630) 257-1580

57  
P1  
5-  
my  
BHK