

# UNOFFICIAL COPY

00697525

5893/0102 07 001 Page 1 of 1  
2000-09-08 10:15:11  
Cook County Recorder 23.50

VILLAGE OF LEMONT  
418 Main Street  
Lemont, Illinois 60439



00697525

## CERTIFICATE OF COMPLIANCE

DATE OF INSPECTION: June 29, 1999

TYPE OF INSPECTION: Water/Sewer Violation Correction

PLUMBING INSPECTOR: Patrick M. Demott

OWNER: George Rimbo

ADDRESS: 74 Timberline Drive P.I.N. 22-10-206-013


FIRM RESPONSIBLE FOR CORRECTION: Hoppy's Landscaping/Affordable Plumbing

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation:  YES  NO

Materials in compliance with 77 Ill. Adm. Code 890. Table D  YES  NO

Water and Sewer Separation: 10 Feet 8 Inches

COMMENTS: The separation violation at the above listed address has been corrected and is in full compliance.

  
Signature of Plumbing Inspector

Prepared by and Return to:  
Village of Lemont  
Building Department  
418 Main Street  
Lemont, Illinois 60439  
(630) 257-1580

5-7  
P-1  
5-  
M-y  
JHC