

UNOFFICIAL COPY 00697527

8893/0104 07 001 Page 1 of 1
2000-09-08 10:15:29
Cook County Recorder 23.50

VILLAGE OF LEMONT
418 Main Street
Lemont, Illinois 60439



00697527

CERTIFICATE OF COMPLIANCE

DATE OF INSPECTION: June 7, 1999

TYPE OF INSPECTION: Water/Sewer Violation Correction

PLUMBING INSPECTOR: Patrick M. Dermott

OWNER: Ron Haynes

ADDRESS: 89 Timberline Drive P.I.N. 22-10-205-002

FIRM RESPONSIBLE FOR CORRECTION: Hoppy's Landscaping/Affordable Plumbing

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation: YES NO

Materials in compliance with 77 Ill. Adm. Code 890.Table D YES NO

Water and Sewer Separation: Exceeds 10 Foot minimum requirement

COMMENTS: The separation violation at the above listed address has been corrected and is in full compliance.

Signature of Plumbing Inspector

Prepared by and Return to:
Village of Lemont
Building Department
418 Main Street
Lemont, Illinois 60439
(630) 257-1580

by
P1
5-
my
JLH