

UNOFFICIAL COPY

0010062077

2/31/0133 51 001 Page 1 of 1

2001-01-24 12:47:32

Cook County Recorder 23.50

VILLAGE OF LEMONT
418 Main Street
Lemont, Illinois 60439



CERTIFICATE OF COMPLIANCE

DATE OF INSPECTION: March 24, 1999

TYPE OF INSPECTION: Water/Sewer Code Compliance

PLUMBING INSPECTOR: Martin Hajmacer

OWNER: Charles Lynch

ADDRESS: 3 Cedar Court P.I.N. 22-30-207-021

FIRM RESPONSIBLE FOR CORRECTION: N/A

Water/Sewer Lines Comply with 77 Ill. Adm. Code 890.1150 and 35 Ill. Adm. Code 653.119 for horizontal separation: X YES NO

Materials in compliance with 77 Ill. Adm. Code 890.Table D X YES NO

Water and Sewer Separation: 15 Feet 3 Inches

COMMENTS: Sewer and water are 15 Feet 3 Inches apart.

Martin Hajmacer
Signature of Plumbing Inspector

Prepared by and Return to:
Village of Lemont
Building Department
418 Main Street
Lemont, Illinois 60439
(630) 257-1580

*Sub
R1
m/yes
aw*