

Space reserved for Recorder's Office only

Doc#: 0809235263 Fee: \$40.00 Eugene "Gene" Moore

Cook County Recorder of Deeds Date: 04/01/2008 02:45 PM Pg: 1 of 3

IN THE CITY OF CHICAGO, ILLINOIS DEPARTMENT OF ADMINISTRATIVE HEARINGS

	2101/11/101	icilive meannings
CITY OF CHICAGO, a Municipal	Corporation,)
100 Parties	Plaintiff,) Docket Number:) 07BS14210A
Rosemary Townsend		Issuing City Department:Buildings
C	Defendants.)
RECORDING OF FI	NDINGS, DE	CISION AND ORDER
through its attorney the Corp Corporation Counsel, Gold incorporated certified Finding Law Officer pursuant to an ac	poration Coun man and Gi s, Decisions a dministrative	GO, a municipal corporation, by and sci, by and through Special Assistant rant, hereby files the attached and and Order entered by an Administrative hearing in the above captioned matter. the Cook County Recorder of Deeds as
PIN#: 20-35-116-004	Name	: Rosemary Townsend
Address: 8117 S Drexel Ave	City: (Chicago
State: IL	Zip: 6	50619
Legal Description: LOT: 39-41; BLO SEC/TWN/RNG/MER: S26&35T38		BDIVISION: CORNELL;
Goldman and Grant #36689		

205 W. Randolph, STE 1100 Chicago, IL. 60606 (312) 781-8700

UNOFFICIAL COP

(1/00)

IN THE CITY OF CHICAGO, ILLINOIS DEPARTMENT OF ADMINISTRATIVE HEARINGS

		Address of Violation:
CITY OF CHICAGO, a Municipal Corporation	, Petitioner,)	8117 S Drexel Avenue
ν.)	
*•)	
Rosemary Townsend)	Docket #: 07BS14210A
1740 E. 73RD ST.)	
CHICAGO, IL 60649)	Issuing City
and)	Department: Buildings
Rosemary Townsend)	
8117 S. DREXEL AVE)	
CHICAGO, IL 60619)	
	Respondents.)	

This matter coming for Hearing, notice given and the Administrative Body advised in the premises, having considered the motions, evidence and arguments presented, IT (S CRDERED: As to the count(s), this tribunal finds by a preponderance of the evidence and rules as follows:

<u>Finding</u>	<u>NOV#</u>	Count(s) Municipal Code Violated	<u>Penalties</u>
Default - Liable by prove-up	07SO140316	1 197019 Install and maintain approved smoke detectors. (13-196-100 thru 13-196-160) Install a smoke detector in every dwelling unit. Install one on any living level with a habitable room or unenclosed heating plant, on the uppermost ceiling of encircled porch stairwell, and within 15 feet of every sleeping room. Be sure the detector is at least 4 inches from the wall, 4 to 12 inches from the ceiling, and not above door or window.	\$500.00
I hereby certify the foregoing to be a of an Order entered by an Administra Chicago Department of Administrative	MAG PSM OTHERS OF	 2 015012 Equip exit door with door lock hardware so door opens without key from side of egress. (13-160-260) 3 105015 Repair or replace defective door. (13-196-550) 	\$500.00 \$500.00

4 070024 Repair or replace defective or missing members of porch

5 079014 Repair or rebuild defective members of garage or shed. (13-96-

system. (13-196-570)

380, 13-96-250)

Above must best an original signature to be accepted as a Certified Copy.

Sanction(s):

07BS14210A

\$500.00

\$500.00

Page 1 of 2

Date Printed: Feb 13, 2008 9:43 am

DOAH - Order

UNOFFICIAL COP



(1/00)

IN THE CITY OF CHICAGO, ILLINOIS DEPARTMENT OF ADMINISTRATIVE HEARINGS

Admin Costs: \$40.00

JUDGMENT TOTAL: \$2,540.00

Balance Due: \$2,540.00

Respondent is ordered to come into immediate compliance with any/all outstanding Code violations.

Respondent being found liable by default has 21 days from the above stamped mailing date to file a petition to vacate (void) this default for good cause, with the Department of Administrative Hearings.

Administrative Law Officer

23

Dec 12, 2007

ALO#

Date

You may appeal this Order to the Circuit Court of Cock Co. (Daley Center 6th Fl.) within 35 days by filing a civil law suit Sounty Clark's Office and by paying the appropriate State mandated filing fee: .

07BS14210A

Page 2 of 2

Date Printed: Feb 13, 2008 5:43 am