



Space reserved for Recorder's Office only

Doc#: 0913226247 Fee: \$40.00  
Eugene "Gene" Moore  
Cook County Recorder of Deeds  
Date: 05/12/2009 02:25 PM Pg: 1 of 3

IN THE CITY OF CHICAGO, ILLINOIS  
DEPARTMENT OF ADMINISTRATIVE HEARINGS

CITY OF CHICAGO, a Municipal Corporation, )  
)  
Plaintiff, )  
)  
)  
)  
*Lashaun Harter* )  
)  
Defendants. )

Docket Number:  
**09BS00151A**

Issuing City Department:  
Buildings

RECORDING OF FINDINGS, DECISION AND ORDER

1. The petitioner, **THE CITY OF CHICAGO**, a municipal corporation, by and through its attorney the Corporation Counsel, by and through Special Assistant Corporation Counsel, **Goldman and Grant**, hereby files the attached and incorporated certified Findings, Decisions and Order entered by an Administrative Law Officer pursuant to an administrative hearing in the above captioned matter. This Certified copy is being recorded with the Cook County Recorder of Deeds as provided for by law.

PIN#: **16-14-310-023**

Name: **Lashaun Harter**

Address: **3846 W Polk St**

City: **Chicago**

State: **IL**

Zip: **60624**

Legal Description: **LOT NUMBER: 64; SUBDIVISION: GARFIELD BLVD ADD TO CHICAGO SW SEC; DISTRICT: 77; UNIT: 2; CITY/MUNI/TWNSP: WEST CHICAGO; SEC/TWN/RNG/MER: SEC 14 TWN 39N RNG 13E; MAP: 16-14-SW (E&F)**

**Goldman and Grant #36689  
205 W. Randolph, STE 1100  
Chicago, IL. 60606  
(312) 781-8700**

# UNOFFICIAL COPY



## IN THE CITY OF CHICAGO, ILLINOIS DEPARTMENT OF ADMINISTRATIVE HEARINGS

<p><b>CITY OF CHICAGO</b>, a Municipal Corporation, Petitioner, )                  v. )                  )                  Lashaun S Harter A/K/A Lashaun S Shorter )                  3846 W POLK ST )                  CHICAGO, IL 60612 )                  and )                  Lashaun S Harter A/K/A Lashaun S Shorter )                  540 BARCLAY DR )                  BOLINGBROOK, IL 60440 )                  )                  , Respondents. )</p>	<p>Address of Violation:                  3846 W Polk Street</p> <p>Docket #: 09BS00151A</p> <p>Issuing City                  Department: Buildings</p>
--	---

### FINDINGS, DECISIONS & ORDER

This matter coming for Hearing, notice given and the Administrative Body advised in the premises, having considered the motions, evidence and arguments presented, IT IS ORDERED: As to the count(s), this tribunal finds by a preponderance of the evidence and rules as follows:

<u>Finding</u>	<u>NOV#</u>	<u>Count(s)</u>	<u>Municipal Code Violated</u>	<u>Penalties</u>
Default - Liable by prove-up	09HW190830	1	154027 Supply adequate hot water with minimum temperature of 120 degrees F. (13-196-430)	\$500.00
		2	17019 Install and maintain approved smoke detectors. (13-196-100 thru 13-196-160) Install a smoke detector in every dwelling unit. Install one on any living level with a habitable room or an enclosed heating plant, on the uppermost ceiling of enclosed porch, stairwell, and within 15 feet of every sleeping room. Be sure the detector is at least 4 inches from the wall, 4 to 12 inches from the ceiling, and not above door or window.	\$500.00
		3	197087 Install carbon monoxide detector within 40 feet of every sleeping room in residential structure. (13-64-190, 13-64-210) A carbon monoxide detector is needed whenever there is a heating appliance on the premises that burns fossil fuel such as gas, oil, or coal, or air that is circulated through a heat exchanger. Install according to manufacturer instructions. A hard wired model requires an	\$500.00

I hereby certify the foregoing to be a true and correct copy of an Order entered by an Administrative Law Officer of Chicago Department of Administrative Hearings.

*M. A. [Signature]*  
 Certified clerk

Date 5/6/09

This copy or original document to be accepted as a Certified Copy

**UNOFFICIAL COPY**

**IN THE CITY OF CHICAGO, ILLINOIS  
DEPARTMENT OF ADMINISTRATIVE HEARINGS**

<u>Finding</u>	<u>NOV#</u>	<u>Count(s)</u>	<u>Municipal Code Violated</u>	<u>Penalties</u>
Default - Liable by prove-up	09HW190830		electrical wiring permit. In a single family residence, be sure the detector is on or below the lowest floor with a place to sleep. In a multiple dwelling residence heated by a boiler, install a detector in the same room as the boiler. Otherwise, each apartment follows single family guidelines. The owner is responsible for installation and written instructions, the tenant for testing, maintenance, and batteries.	

**Sanction(s):****Admin Costs:** \$40.00**JUDGMENT TOTAL:** \$1,540.00**Balance Due:** \$1,540.00

Respondent is ordered to come into immediate compliance with any/all outstanding Code violations.

Respondent being found liable by default has 21 days from the above stamped mailing date to file a petition to vacate (void) this default for good cause, with the Department of Administrative Hearings.

*Rafel Reyna*

ENTERED:

Administrative Law Officer

98

ALO#

Jan 20, 2009

Date

You may appeal this Order to the Circuit Court of Cook Co. (Daley Center 6th Fl.) within 35 days by filing a civil law suit and by paying the appropriate State mandated filing fees.