



Doc#: 1017612197 Fee: \$40.00  
Eugene "Gene" Moore  
Cook County Recorder of Deeds  
Date: 06/25/2010 02:24 PM Pg: 1 of 3

Space reserved for Recorder's  
Office only

**IN THE CITY OF CHICAGO, ILLINOIS  
DEPARTMENT OF ADMINISTRATIVE HEARINGS**

**CITY OF CHICAGO**, a Municipal Corporation, )  
)  
Plaintiff, )  
)  
)  
*John H. Banks* )  
)  
Defendants. )

Docket Number:  
**10BS01201A**

Issuing City Department:  
Building

**RECORDING OF FINDINGS, DECISION AND ORDER**

1. The petitioner, **THE CITY OF CHICAGO**, a municipal corporation, by and through its attorney the Corporation Counsel, by and through Special Assistant Corporation Counsel, **Goldman and Grant**, hereby files the attached and incorporated certified Findings, Decisions and Order entered by an Administrative Law Officer pursuant to an administrative hearing in the above captioned matter. This Certified copy is being recorded with the Cook County Recorder of Deeds as provided for by law.

PIN#: **20-18-425-044**

Name: **John H. Banks**

Address: **6217 S. Winchester Ave**

City: **Chicago**

State: **IL**

Zip: **60636**

Legal Description: **LOT NUMBER: 29; SUBDIVISION: E A CUMMINGS & COMPANY'S 63RD STREET; SEC/TWN/RNG/MER: SEC 18 TWN 38N RNG 14E; MAP: 20-18-SE (G&H)**

**Goldman and Grant #36689  
205 W. Randolph, STE 1100  
Chicago, IL. 60606  
(312) 781-8700**

# UNOFFICIAL COPY



## IN THE CITY OF CHICAGO, ILLINOIS DEPARTMENT OF ADMINISTRATIVE HEARINGS

CITY OF CHICAGO, a Municipal Corporation, Petitioner, )  
 v. )  
 )  
 John H Banks )  
 5529 S ASHLAND AVE )  
 CHGO, IL 60636 )  
 and )  
 John H Banks )  
 6217 S WINCHESTER AVE )  
 CHGO, IL 60636 )  
 and )  
 John H Banks )  
 6700 S SOUTH SHORE DR #8G )  
 CHGO, IL 60649 )  
 Respondents. )

Address of Violation:  
 6217 S Winchester Avenue  
 Docket #: 10BS01201A  
 Issuing City  
 Department: Buildings

### FINDINGS, DECISIONS & ORDER

This matter coming for Hearing, notice given and the Administrative Body advised in the premises, having considered the motions, evidence and arguments presented, IT IS ORDERED: As to the count(s), this tribunal finds by a preponderance of the evidence and rules as follows:

<u>Finding</u>	<u>NOV#</u>	<u>Count(s)</u>	<u>Municipal Code Violated</u>	<u>Penalties</u>
Liabe - By plea	10SO242818	3	197019 install and maintain approved smoke detectors. (13-196-100 thru 13-196-160) Install a smoke detector in every dwelling unit. Install one on any living level with a habitable room or unenclosed heating plant, on the uppermost ceiling of enclosed porch stair well and within 15 feet of every sleeping room. Be sure the detector is at least 4 inches from the wall, 4 to 12 inches from the ceiling, and not above door or window.	\$200.00
		4	197087 Install carbon monoxide detector within 40 feet of every sleeping room in residential structure. (13-64-190, 13-64-210) A carbon monoxide detector is needed whenever there is a heating appliance on the premises that burns fossil fuel such as gas, oil, or coal, or air that is circulated through a heat exchanger. Install according to manufacturer instructions. A	\$200.00

I hereby certify the foregoing to be a true and correct copy of an Order entered by an Administrative Law Judge of the Chicago Department of Administrative Hearings.

*B. Byler* 6-1-2010  
 Authorized clerk Date

Above must bear an original signature to be accepted as an Certified Copy

**UNOFFICIAL COPY**

**IN THE CITY OF CHICAGO, ILLINOIS  
DEPARTMENT OF ADMINISTRATIVE HEARINGS**

<u>Finding</u>	<u>NOV#</u>	<u>Count(s)</u>	<u>Municipal Code Violated</u>	<u>Penalties</u>
Liabe - By plea	10SO242818		hard wired model requires an electrical wiring permit. In a single family residence, be sure the detector is on or below the lowest floor with a place to sleep. In a multiple dwelling residence heated by a boiler, install a detector in the same room as the boiler. Otherwise, each apartment follows single family guidelines. The owner is responsible for installation and written instructions, the tenant for testing, maintenance, and batteries.	
Not liable - Respondent came into compliance with building code prior to hearing	10SO242818	1	132016 Heat dwelling unit adequately from September 15th to June 1st. (13-196-410)	\$0.00
		2	132046 Provide and maintain every facility, piece of equipment, or utility in safe and sound working condition. (13-196-400, 13-196-440)	\$0.00

**Sanction(s):**

Admin Costs: \$40.00

**JUDGMENT TOTAL: \$440.00****Balance Due: \$440.00**

Respondent is ordered to come into immediate compliance with any/all outstanding Code violations.

ENTERED: \_\_\_\_\_

Administrative Law Judge

70

ALO#

Mar 10, 2010

Date

**You may appeal this Order to the Circuit Court of Cook Co. (Daley Center 6th Fl.) within 35 days by filing a civil law suit and by paying the appropriate State mandated filing fees.**

**Pursuant to Municipal Code Chapter 1-19, the city's collection costs and attorney's fees shall be added to the balance due if the debt is not paid prior to being referred for collection.**