

# UNOFFICIAL COPY



PREPARED BY:

Name: GF Office Furniture Ltd., L.P.

Address: 1034 South Kostner  
Chicago, IL 62624

Doc#: 1023618002 Fee: \$68.00  
Eugene "Gene" Moore RHSP Fee: \$10.00  
Cook County Recorder of Deeds  
Date: 08/24/2010 10:16 AM Pg: 1 of 17

RETURN TO:

Name: GF Office Furniture Ltd., L.P.  
Attn: Vytas Ambutas

Address: 1965 Pratt Boulevard  
Elk Grove Village, IL 60007

(THE ABOVE SPACE FOR RECORDER'S OFFICE)

## LEAKING UNDERGROUND STORAGE TANK ENVIRONMENTAL NOTICE

THE OWNER AND/OR OPERATOR OF THE LEAKING UNDERGROUND STORAGE TANK SYSTEM(S) ASSOCIATED WITH THE RELEASE REFERENCED BELOW, WITHIN 45 DAYS OF RECEIVING THE NO FURTHER REMEDIATION LETTER CONTAINING THIS NOTICE, MUST SUBMIT THIS NOTICE AND THE REMAINDER OF THE NO FURTHER REMEDIATION LETTER TO THE OFFICE OF THE RECORDER OR REGISTRAR OF TITLES OF COOK COUNTY IN WHICH THE SITE DESCRIBED BELOW IS LOCATED.

Illinois EPA Number: 0316230003

Leaking UST Incident No.: 20091152

GF Office Furniture Ltd., L.P., the owner and/or operator of the leaking underground storage tank system(s) associated with the above-referenced incident, whose address is 1965 Pratt Boulevard, Elk Grove Village, IL 60007, has performed investigative and/or remedial activities for the site identified as follows:

1. Legal Description or Reference to a Plat Showing the Boundaries: See attached.
2. Common Address: 1034 South Kostner, Chicago, IL 62624
3. Real Estate Tax Index/Parcel Index Number: 16-15-325-003, 16-15-325-004 & 16-15-325-005
4. Site Owner: GF Office Furniture Ltd., L.P.
5. Land Use Limitation: **The land use shall be industrial/commercial.**
6. See the attached No Further Remediation Letter for other terms.

HAC:JD

Attachment: Legal Description

**UNOFFICIAL COPY**

**GF OFFICE FURNITURE, LTD. L.P.  
1034 S. KOSTNER AVENUE  
CHICAGO, ILLINOIS**

**PARCEL 4**

THAT PART OF THE EAST HALF OF THE SOUTHWEST QUARTER OF SECTION 15, TOWNSHIP 39 NORTH, RANGE 13 EAST OF THE THIRD PRINCIPAL MERIDIAN DESCRIBED AS FOLLOWS:

COMMENCING AT A POINT IN THE NORTH LINE OF WEST FILLMORE STREET 401.25 FEET WEST OF THE INTERSECTION OF SAID NORTH LINE WITH THE WEST LINE OF SOUTH KOSTNER AVENUE, AND RUNNING;

THENCE WEST 233.05 FEET ALONG SAID NORTH LINE OF WEST FILLMORE STREET TO A POINT WHICH IS IDENTICAL WITH WHAT WAS FORMERLY THE CENTER LINE OF SOUTH KILBOURN AVENUE, (NOW VACATED);

THENCE NORTH ON SAID CENTER LINE 148.27 FEET (MORE OR LESS) TO THE SOUTH LINE OF THE RIGHT OF WAY OF THE CHICAGO, GREAT WESTERN RAILROAD;

THENCE EASTERLY 233.05 FEET (MORE OR LESS) ALONG THE SOUTH LINE OF SAID RIGHT OF WAY TO A POINT 401.25 FEET WEST LINE OF SAID SOUTH KOSTNER AVENUE (MEASURED ON A LINE PARALLEL WITH SAID NORTH LINE OF FILLMORE STREET);

THENCE SOUTH 148.27 FEET TO THE PLACE BEGINNING;

(EXCEPT THAT PART OF SAID TRACT DESCRIBED AS FOLLOWS:

COMMENCING AT A POINT IN THE NORTH LINE OF WEST FILLMORE STREET, AND THE CENTER LINE OF VACATED SOUTH KILBOURN AVENUE;

THENCE NORTH ALONG THE CENTER LINE OF SAID VACATED STREET 148.90 FEET TO THE SOUTH LINE OF THE CHICAGO AND GREAT WESTERN RAILROAD,

THENCE EAST ALONG THE SOUTH LINE OF SAID RAILROAD 82.33 FEET;

THENCE SOUTH ON A LINE WHICH PASSES THROUGH THE CENTER OF AN EXISTING TWELVE INCH BRICK WALL 148.64 FEET TO THE NORTH LINE OF WEST FILLMORE STREET;

THENCE WEST ALONG THE NORTH LINE OF SAID STREET 82.26 FEET TO THE POINT OF BEGINNING) IN COOK COUNTY, ILLINOIS.

**PARCEL 5**

THAT PART OF BLOCK 1 NOW VACATED SHOWN ON THE PLAT THEREOF AS LOTS 1 THROUGH 16, BOTH INCLUSIVE, AND A STRIP OF LAND 16 FEET WIDE NORTH OF AND ADJOINING SAID TRACT IN D.S. PLACE'S THIRD ADDITION TO CHICAGO, A SUBDIVISION OF THE EAST HALF OF THE SOUTHEAST QUARTER OF SECTION 15, TOWNSHIP 39 NORTH, RANGE 13 EAST OF THE THIRD PRINCIPAL MERIDIAN, LYING SOUTH OF THE RIGHT OF WAY OF THE CHICAGO AND GREAT WESTERN RAILROAD (EXCEPT THE WEST 33 FEET THEREOF) IN COOK COUNTY, ILLINOIS.

CONTAINING IN THE AGGREGATE 81,615 SQUARE FEET (1.8736 ACRES) OF LAND, MORE OR LESS.



# UNOFFICIAL COPY

## ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 North Grand Avenue East, P.O. Box 19276, Springfield, Illinois 62794-9276 • (217) 782-2329  
James R. Thompson Center, 100 West Randolph, Suite 11-300, Chicago, IL 60601 • (312) 814-6026

PAT QUINN, GOVERNOR

DOUGLAS P. SCOTT, DIRECTOR

217/782-6762

CERTIFIED MAIL

AUG 12 2010

7009 2820 0001 7491 8569

GF Office Furniture Ltd., L.P.  
Attn: Vytas Ambutas  
1965 Pratt Boulevard  
Elk Grove Village, IL 60007

Re: LPC #0316230003 -- Cook County  
Chicago/GF Office Furniture Ltd., L.P.  
1034 South Kostner  
Leaking UST Incident No. 20091152  
Leaking UST Technical File

Dear Mr. Ambutas:

The Illinois Environmental Protection Agency (Illinois EPA) has reviewed the Corrective Action Completion Report submitted for the above-referenced incident. This information was dated June 25, 2010 and was received by the Illinois EPA on June 25, 2010. Citations in this letter are from the Environmental Protection Act (Act), as amended by Public Act 92-0554 on June 24, 2002, and 35 Illinois Administrative Code (35 Ill. Adm. Code).

The Corrective Action Completion Report and associated Licensed Professional Engineer Certification submitted pursuant to Section 57.7(b)(5) of the Act and 35 Ill. Adm. Code 734.135(d) indicate corrective action for the above-referenced site was conducted in accordance with the Corrective Action Plan approved by the Illinois EPA. The Corrective Action Completion Report demonstrates that the requirements of Section 57.7(b) of the Act have been satisfied.

Based upon the certification by Henry Adamiak, a Licensed Professional Engineer, and pursuant to Section 57.10 of the Act (415 ILCS 5/57.10), your request for a no further remediation determination is granted under the conditions and terms specified in this letter.

Issuance of this No Further Remediation Letter (Letter), based on the certification of the Licensed Professional Engineer, signifies that: (1) all statutory and regulatory corrective action requirements applicable to the occurrence have been complied with; (2) all corrective action concerning the remediation of the occurrence has been completed; and (3) no further corrective action concerning the occurrence is necessary for the protection of human health, safety, and the environment. Pursuant to Section 57.10(d) of the Act, this Letter shall apply in favor of the following parties:

1. GF Office Furniture Ltd., L.P., the owner or operator of the underground storage tank system(s).
2. Any parent corporation or subsidiary of such owner or operator.
3. Any co-owner or co-operator, either by joint tenancy, right-of-survivorship, or any other party sharing a legal relationship with the owner or operator to whom the Letter is issued.

Rockford • 4302 N. Main St., Rockford, IL 61103 • (815) 987-7760  
Elgin • 595 S. State, Elgin, IL 60123 • (847) 608-3131  
Bureau of Land – Peoria • 7620 N. University St., Peoria, IL 61614 • (309) 693-5462  
Collinsville • 2009 Mall Street, Collinsville, IL 62234 • (618) 346-5120

Des Plaines • 9511 W. Harrison St., Des Plaines, IL 60016 • (847) 294-4000  
Peoria • 5415 N. University St., Peoria, IL 61614 • (309) 693-5463  
Champaign • 2125 S. First St., Champaign, IL 61820 • (217) 278-5800  
Marion • 2309 W. Main St., Suite 116, Marion, IL 62959 • (618) 993-7200

# UNOFFICIAL COPY

Page 2

4. Any holder of a beneficial interest of a land trust or inter vivos trust whether revocable or irrevocable.
5. Any mortgagee or trustee of a deed of trust of such owner or operator.
6. Any successor-in-interest of such owner or operator.
7. Any transferee of such owner or operator whether the transfer was by sale, bankruptcy proceeding, partition, dissolution of marriage, settlement or adjudication of any civil action, charitable gift, or bequest.
8. Any heir or devisee of such owner or operator.
9. An owner of a parcel of real property to the extent that this Letter applies to the occurrence on that parcel.

This Letter and all attachments, including but not limited to the Leaking Underground Storage Tank Environmental Notice, must be filed within 45 days of receipt as a single instrument with the Office of the Recorder or Registrar of Titles in the county in which the above-referenced site is located. In addition, the Groundwater Ordinance (photocopy attached) must be filed as an attachment of this Letter with the Office of the Recorder or Registrar of Titles of the applicable county. This Letter shall not be effective until officially recorded by the Office of the Recorder or Registrar of Titles of the applicable county in accordance with Illinois law so it forms a permanent part of the chain of title for the above-referenced property. Within 30 days of this Letter being recorded, an accurate and official copy of this Letter, as recorded, shall be obtained and submitted to the Illinois EPA. For recording purposes, it is recommended that the Leaking Underground Storage Tank Environmental Notice of this Letter be the first page of the instrument filed.

## CONDITIONS AND TERMS OF APPROVAL

### LEVEL OF REMEDIATION AND LAND USE LIMITATIONS

1. The remediation objectives have been established in accordance with an industrial/commercial land use limitation. The remediation objectives for the above-referenced site, more particularly described in the Leaking Underground Storage Tank Environmental Notice of this Letter, were established in accordance with the requirements of the Tiered Approach to Corrective Action Objectives (35 Ill. Adm. Code 742) rules.
2. As a result of the release from the underground storage tank system(s) associated with the above-referenced incident, the above-referenced site, more particularly described in the attached Leaking Underground Storage Tank Environmental Notice of this Letter, shall not be used in a manner inconsistent with the following land use limitation: The land use shall be industrial/commercial. It has been demonstrated that the groundwater under the site meets Class II (General Resource) groundwater criteria rather than Class I (Potable Resource) groundwater. Groundwater classifications are defined at 35 Ill. Adm. Code 620.Subpart B.

# UNOFFICIAL COPY

Page 3

3. The land use limitation specified in this Letter may be revised if:
  - a. Further investigation or remedial action has been conducted that documents the attainment of objectives appropriate for the new land use; and
  - b. A new No Further Remediation Letter is obtained and recorded in accordance with Title XVII of the Act and regulations adopted thereunder.

## PREVENTIVE, ENGINEERING, AND INSTITUTIONAL CONTROLS

4. **Preventive:** Prior to commencement of any future excavation and/or construction in or near the contaminated zone of the remediation site, a safety plan for this remediation site is required that is consistent with the National Institute for Occupational Safety and Health Guidance Manual for Hazardous Waste Site Activities; Occupational Safety and Health Administration regulations, particularly in 29 CFR 1910 and 1926; state and local regulations; and other U.S. EPA guidance as provided. At a minimum, the plan should address possible worker exposure if any future excavation and construction activities occur within the contaminated soil.
  
- Engineering:** A three-foot thick clean soil barrier must be maintained within three (3) feet of the land surface to inhibit the ingestion of the contaminated media, as outlined in the area of concern on the attached Site Base Map.  
A building barrier that is sufficient in thickness to inhibit the inhalation and ingestion of the contaminated media must remain over the contaminated soil as outlined in the attached Site Base Map. This building barrier is to be properly maintained as an engineered barrier to inhibit inhalation and ingestion of the contaminated media.
  
- Institutional:** This Letter shall be recorded as a permanent part of the chain of title for the above-referenced site, more particularly described in the attached Leaking Underground Storage Tank Environmental Notice of this Letter.

### Groundwater Use Ordinance

Section 11-8-390 of the Municipal Code of Chicago effectively prohibits the installation of potable water supply wells (and the use of such wells) and is an acceptable institutional control under the following conditions:

Each affected or potentially affected (as shown through contaminant modeling) property owner and the City of Chicago must receive written notification from the owner or operator desiring to use the ordinance as an institutional control that groundwater remediation objectives have been approved by the Illinois EPA. Written proof of this notification shall be submitted to the Illinois EPA in accordance with 35 Ill. Adm. Code 742.1015(b) and (c) within 45 days from the date this Letter is recorded. The notification shall include:

# UNOFFICIAL COPY

Page 4

- a. The name and address of the unit of local government;
- b. The citation of the ordinance used as an institutional control in this Letter;
- c. A description of the property being sent notice by adequate legal description or by reference to a plat showing the boundaries;
- d. A statement that the ordinance restricting the groundwater use was used by the Illinois EPA in reviewing a request for groundwater remediation objectives;
- e. A statement as to the nature of the release and response action with the name, address, and Illinois EPA inventory identification number; and
- f. A statement as to where more information may be obtained regarding the ordinance.

The following activities shall be grounds for avoidance of the ordinance as an institutional control and this Letter:

- a. Modification of the reference ordinance to allow potable uses of groundwater.
- b. Approval of a site-specific request, such as a variance, to allow use of groundwater at the site.
- c. Violation of the terms of a recorded institutional control.

As a part of its corrective action, the leaking underground storage tank site has relied upon Section 11-8-390 of the Municipal Code of Chicago that prohibits potable uses of groundwater as defined therein.

5. Failure to establish, operate, and maintain controls in full compliance with the Act, applicable regulations, and the approved corrective action plan, if applicable, may result in avoidance of this Letter.

## OTHER TERMS

6. Any contaminated soil or groundwater removed or excavated from, or disturbed at, the above-referenced site, more particularly described in the Leaking Underground Storage Tank Environmental Notice of this Letter, must be handled in accordance with all applicable laws and regulations under 35 Ill. Adm. Code Subtitle G.



# UNOFFICIAL COPY

Page 5

7. Further information regarding the above-referenced site can be obtained through a written request under the Freedom of Information Act (5 ILCS 140) to:

Illinois Environmental Protection Agency  
Attention: Freedom of Information Act Officer  
Bureau of Land - #24  
1021 North Grand Avenue East  
Post Office Box 19276  
Springfield, IL 62794-9276

8. Pursuant to 35 Ill. Adm. Code 734.720, should the Illinois EPA seek to void this Letter, the Illinois EPA shall provide Notice of Voidance to the owner or operator of the leaking underground storage tank system(s) associated with the above-referenced incident and the current title holder of the real estate on which the tanks were located, at their last known addresses. The notice shall specify the cause for the voidance, explain the provisions for appeal, and describe the facts in support of the voidance. Specific acts or omissions that may result in the voidance of this Letter include, but shall not be limited to:

- a. Any violation of institutional controls or industrial/commercial land use restrictions;
- b. The failure to operate and maintain preventive or engineering controls or to comply with any applicable groundwater monitoring plan;
- c. The disturbance or removal of contamination that has been left in-place in accordance with the Corrective Action Plan or Completion Report;
- d. The failure to comply with the recording requirements for the Letter;
- e. Obtaining the Letter by fraud or misrepresentation; or
- f. Subsequent discovery of contaminants, not identified as part of the investigative or remedial activities upon which the issuance of the Letter was based, that pose a threat to human health or the environment.

Submit an accurate and official copy of this Letter, as recorded, to:

Illinois Environmental Protection Agency  
Bureau of Land - #24  
Leaking Underground Storage Tank Section  
1021 North Grand Avenue East  
Post Office Box 19276  
Springfield, IL 62794-9276

# UNOFFICIAL COPY

Page 6

If you have any questions or need further assistance, please contact the Illinois EPA project manager, Jason Donnelly, at (217) 557-8764.

Sincerely,



Harry A. Chappel, P.E.  
Unit Manager  
Leaking Underground Storage Tank Section  
Division of Remediation Management  
Bureau of Land

HAC:JD\091152-NFR.doc

Attachments: City of Chicago Groundwater Ordinance w/ MOU  
Engineered Barrier Map  
Leaking Underground Storage Tank Environmental Notice  
Legal Description

c: Remediation Technologies, Ltd., Henry Adamiak  
BOL File

Property of Cook County Clerk's Office



# UNOFFICIAL COPY

The following is said ordinance as passed:

*Be It Ordained by the City Council of the City of Chicago:*

SECTION 1. Chapter 11-8 of the Municipal Code of Chicago is hereby amended by adding a new Section 11-8-385 and by amending Section 11-8-390 by inserting the language in italics, as follows:

*11-8-385 Potable Water Defined.*

*Potable water is any water used for human consumption, including, but not limited to, water used for drinking, bathing, washing dishes, preparing foods and watering gardens in which produce intended for human consumption is grown.*

*11-8-390 Prohibited Use Of Secondary Water; Prohibited Installation Of New Potable Water Supply Wells.*

No secondary water shall overflow into or be discharged into any surge tank, storage tank, or reservoir or shall in any way be piped or conveyed into the water supply system of any building, structure, or premises to become a part of or be mixed with the fresh water supply from the mains of the Chicago Waterworks System either inside of the premises or in the water service pipe. Secondary water shall not be piped to or used in any plumbing fixture, or for cooling crushers, rollers, or mixers where foods, candies, liquids or materials are manufactured for human or animal consumption. No connection, tap, or opening shall be made in a water distribution system other than an approved water distribution system which will permit such water being used for drinking.

Wherever the fire-protective equipment in any building, structure or premises has service from the Chicago Waterworks System, no pipe or other conduit which conveys secondary water shall be cross-connected to the fire-protective equipment. All fire-protective equipment connected to the Chicago Waterworks System shall be constructed in such manner that

ORIGINAL

# UNOFFICIAL COPY

all tanks, pipes, pumps, surge tanks, and fire hydrants can be thoroughly drained, flushed and cleaned by the owners of such equipment and premises and there shall be no direct connections from the tanks, pipes and other equipment to any drainage pipes or sewers. *No groundwater well, cistern or other groundwater collection device installed after the effective date of this amendatory ordinance may be used to supply any potable water supply system, except at points of withdrawal by the City of Chicago or by units of local government pursuant to intergovernmental agreement with the City of Chicago.*

SECTION 2. Section 2-30-030 of the Municipal Code of Chicago is hereby amended by deleting the language in brackets and inserting the language in italics, as follows:

2-30-030 Commissioner -- Powers And Duties Designated.

The commissioner of the environment shall have the following powers and duties:

\* \* \* \* \*

(21) To enter into grant agreements, cooperation agreements and other agreements or contracts with governmental entities, private business and civic and community groups necessary to implement the Green Streets Program and other urban forestry, beautification and environmental enhancement programs; *and agreements to implement the State of Illinois Site Remediation Program;*

SECTION 3. This ordinance shall be in full force and effect from and after its passage and approval.

ORIGINAL

# UNOFFICIAL COPY

Form C.C. 19 3M 7-14-64 (172)

STATE OF ILLINOIS, }  
County of Cook. } ss.

I, JAMES J. LASKI, City Clerk of the City of Chicago in the County of Cook and State of Illinois, DO HEREBY CERTIFY that the annexed and foregoing is a true and correct copy of that certain ordinance now on file in my office amending Title 11, Chapter 8 and Title 2, Chapter 30 of Municipal Code of Chicago by establishing the definition and regulation of the potable water supply system and Empowerment of Commissioner of Environment for implementation of State of Illinois Site Remediation Program.

I DO FURTHER CERTIFY that the said ordinance was passed by the City Council of the said City of Chicago on the fourteenth (14th) day of May, A.D. 1997 and deposited in my office on the fourteenth (14th) day of May, A.D. 1997.

I DO FURTHER CERTIFY that the vote on the question of the passage of the said ordinance by the said City Council was taken by yeas and nays and recorded in the Journal of the Proceedings of the said City Council, and that the result of said vote so taken was as follows, to wit: Yeas, 47, Nays, none.

I DO FURTHER CERTIFY that the said ordinance was delivered to the Mayor of the said City of Chicago after the passage thereof by the said City Council, without delay, by the City Clerk of the said City of Chicago, and that the said Mayor did approve and sign the said ordinance on the fourteenth (14th) day of May, A.D. 1997.

I DO FURTHER CERTIFY that the original, of which the foregoing is a true copy, is entrusted to my care for safe keeping, and that I am the lawful keeper of the same.

IN WITNESS WHEREOF, I have hereunto set my hand and affixed the corporate seal of the City of Chicago aforesaid, at the said City, in the

(L.S.) County and State aforesaid, this third (3rd) day of February, A.D. 1998.

ORIGINAL

*James J. Laski*  
JAMES J. LASKI, City Clerk.

ORIGINAL



# UNOFFICIAL COPY



City of Chicago  
Richard M. Daley, Mayor

Department of Environment

Henry L. Henderson  
Commissioner

Twenty-fifth Floor  
30 North LaSalle Street  
Chicago, Illinois 60602-2575  
(312) 744-7606 (Voice)  
(312) 744-6451 (FAX)  
(312) 744-3586 (TTY)  
<http://www.ci.chi.il.us>

July 1, 1997

Mr. Gary P. King  
Manager, Division of Remediation Management  
Bureau of Land  
Illinois Environmental Protection Agency  
1001 N. Grand Avenue, East  
Springfield, IL 62702

Re: Chicago Ordinance No. 097990

Dear Mr. King:

Pursuant to 35 Ill. Adm. Code 742.1015(l)(2), Section 11-8-385 and 11-8-390 of the Municipal Code of Chicago, as amended by Ordinance No. 097990, apply to all areas within the corporate limits of the City of Chicago.

Sincerely,

Henry L. Henderson  
Commissioner

cc: Mort Ames  
Asst. Corp. Counsel



Please Recycle!



SCREENED  
MM

# UNOFFICIAL COPY

**MEMORANDUM OF UNDERSTANDING BETWEEN THE CITY OF CHICAGO, ILLINOIS AND THE ILLINOIS ENVIRONMENTAL PROTECTION AGENCY REGARDING (A) THE USE OF A LOCAL POTABLE WATER SUPPLY WELL ORDINANCE AS AN ENVIRONMENTAL INSTITUTIONAL CONTROL AND (B) THE PROVISION OF INFORMATION RELATING TO "NO FURTHER REMEDIATION" DETERMINATIONS BY THE ILLINOIS ENVIRONMENTAL PROTECTION AGENCY TO THE CITY OF CHICAGO**

## I. PURPOSE AND INTENT

- A. This Memorandum of Understanding ("MOU") is entered into between the City of Chicago, Illinois ("the City") and the Illinois Environmental Protection Agency ("Illinois EPA") for the purpose of (a) satisfying the requirements of 35 Ill. Adm. Code 742.1015 for the use of potable water supply well ordinances as environmental institutional controls and (b) ensuring that the City will be provided with copies of all "No Further Remediation" letters or determinations issued by the Illinois EPA pursuant to specific programs for sites located within the boundaries of Chicago, Illinois, in order to enable the City to maintain a complete and up-to-date registry of sites as required by 35 Ill. Adm. Code 742.1015(i)(5). The Illinois EPA has reviewed Sections 11-8-385 and 11-8-390 of the Municipal Code of Chicago as amended by Ordinance Number 097990 ("Potable Water Supply Well Ordinance"), attached as Attachment A, and has determined that the Municipal Code of Chicago prohibits the installation and use of new potable water supply wells by private entities but will allow the installation of potable water supply wells by the City and other units of local government pursuant to intergovernmental agreements with the City. In such cases, 35 Ill. Adm. Code 742.1015(a) provides that the City may enter into a MOU with the Illinois EPA to allow the use of the ordinance as an institutional control.
- B. The intent of this Memorandum of Understanding is to (a) specify the responsibilities that must be assumed by the City to satisfy the requirements for MOUs as set forth at 35 Ill. Adm. Code 742.1015(i), and (b) require the Illinois EPA to provide the City with copies of all "No Further Remediation" letters or determinations that the Illinois EPA issues for sites located within the City of Chicago to enable the City to maintain a registry of sites pursuant to 35 Ill. Adm. Code 742.1015(i)(5).

## II. DECLARATIONS AND ASSUMPTION OF RESPONSIBILITY

- A. In order to ensure the long-term integrity of the Potable Water Supply Well Ordinance as an environmental institutional control and that risk to human health and the environment from contamination left in place in reliance on the Potable Water Supply Well Ordinance is effectively managed, the City hereby assumes the following responsibilities pursuant to 35 Ill. Adm. Code 742.1015(i):

# UNOFFICIAL COPY

1. The City will notify the Illinois EPA Bureau of Land of any changes to or requests for variance from the Potable Water Supply Well Ordinance at least 30 days prior to the date the local government is scheduled to take action on the proposed change or request (35 Ill. Adm. Code 742.1015(i)(4));
2. The City will maintain a registry of all sites within its corporate limits that have received "No Further Remediation" determinations from the Illinois EPA pursuant to specific programs (35 Ill. Adm. Code 742.1015(i)(5));
3. If the City determines to install a new potable water supply well(s), the City will review the registry of sites established under paragraph II.A.2. prior to siting such potable water supply well(s) within the area covered by the Potable Water Supply Well Ordinance, pursuant to 35 Ill. Adm. Code 742.1015(i)(6)(A);
4. If the City determines to install a new potable water supply well(s), the City will determine whether the potential source of potable water has been or may be affected by contamination left in place at the sites tracked and reviewed under paragraphs II.A.2. and 3. (35 Ill. Adm. Code 742.1015(i)(6)(B)); and
5. If the City determines to install a new potable water supply well(s), the City will take action as necessary to ensure that the potential source of potable water is protected from contamination or treated before it is used as a potable water supply (35 Ill. Adm. Code 742.1015(i)(6)(C));
6. If the City enters into intergovernmental agreements under Section 11-8-390 of the Municipal Code of Chicago to allow other units of local government to install new potable water supply well(s) within the corporate limits of the City, the City will require compliance with the procedures set forth in paragraphs II.A.3., 4., and 5. as a part of such agreements.
7. Notification under paragraph II.A.1. above, or other communications concerning this MOU directed to the Illinois EPA, shall be addressed to:

Manager, Division of Remediation Management  
 Bureau of Land  
 Illinois Environmental Protection Agency  
 P.O. Box 19276  
 Springfield, IL 62794-9276

- B. In order to ensure the long-term integrity of the Potable Water Supply Well Ordinance as an environmental institutional control and that risk to human health and the environment from contamination left in place in reliance on the Potable Water Supply Well Ordinance or other specific programs can be effectively managed, the Illinois EPA hereby assumes

# UNOFFICIAL COPY

the following responsibilities:

1. The Illinois EPA will provide the City with copies of all "No Further Remediation" letters or determinations that it issues pursuant to 35 Ill. Adm. Code 742, and other specific programs, for sites located within the boundaries of the City at the time said letters or determinations are provided to remediation applicants.
2. Copies of "No Further Remediation" letters or determinations provided to the City pursuant to paragraph II.B.1. above, or other communications concerning this MOU directed to the City, shall be addressed to:

Commissioner  
Chicago Department of Environment  
25th Floor  
30 North LaSalle Street  
Chicago, IL 60602-2575

### III. SUPPORTING DOCUMENTATION

The following documentation is required by 35 Ill. Adm. Code 742.1015(i) and is attached to this MOU:

- A. Attachment A: A copy of the Potable Water Supply Well Ordinance certified by the city clerk or other official as the current, controlling law (35 Ill. Adm. Code 742.1015(i)(3)) and a statement of the authority of the City to enter into the MOU (35 Ill. Adm. Code 742.1015(i)(1));
- B. Attachment B: Identification of the legal boundaries within which the Potable Water Supply Well Ordinance is applicable (35 Ill. Adm. Code 742.1015(i)(2)); and



# UNOFFICIAL COPY

IN WITNESS WHEREOF, the lawful representatives of the parties have caused this MOU to be signed as follows:

**FOR: The City of Chicago, Illinois**

BY: *Arvo J. Jansson* DATE: *July 1, 1997*  
Commissioner  
Department of Environment  
City of Chicago


**FOR: Illinois Environmental Protection Agency**

BY: *Gary P. King* DATE: *July 3, 1997*  
(Name and title of signatory)  
Mgr, Division of Remediation Management  
Bureau of Land

Version 6/27/97

Property of Cook County Clerk's Office

UNOFFICIAL COPY



**RemTech**  
 REMEDIATION TECHNOLOGIES, LTD.  
 540 W. FRONTAGE ROAD, NORTHFIELD, IL. 60093

GF OFFICE FURNITURE 1034 S. KOSTNER AVE., CHICAGO, IL. LUST INCIDENT #20091152 LOCATION OF ENGINEERED BARRIER				
APPROV. BY HA	CHECKED BY HA	DRAWN BY DHR	DATE 1/7/10	DWG. No. FIG 5
				REV. 0