Doc#: 1613001096 Fee: \$44.00 Karen A. Yarbrough

Cook County Recorder of Deeds Date: 05/09/2016 02:44 PM Pg: 1 of 4

Space reserved for Recorder's Office only

IN THE CITY OF CHICAGO, ILLINOIS **DEPT OF ADMINISTRATIVE HEARINGS**

The City of Chicago, A Muni Corp.

Plaintiff.

VS.

AYAZ NIAZI

Defendant,

Docket Number: 15BT01065A **Issuing City Department:**

BUILDINGS

RECORDING OF FINDINGS, DECISION AND ORDER

The Petitioner, THE CITY OF CHICAGO, a municipal corporation, by and through its attorney the Corporation Counsel, by and through Special Assistant Corporation Counsel, ROBERTS & WEDDLE, LLC, hereby files the attached and incorporated certified Findings, Decision and Order entered by an Administrative Law Officer pursuant of an administrative hearing in the above captioned matter. This certified copy is being recorded with the Cook County Recorder of Deeds as provided for by law.

AYAZ NIAZI 1461 W. 114TH PL. CHICAGO, IL 60622

PIN #: 25-20-127-009-0000 Legal Description: See Attached

ROBERTS & WEDDLE, LLC 309 W. Washington St. Suite 500 Chicago, IL 60606 312-589-5800

File#: 71799.66422

DOAH - Order

Elm Hann

UNOFFICIAL COPY

(1/00)

IN THE CITY OF CHICAGO, ILLINOIS DEPARTMENT OF ADMINISTRATIVE HEARINGS

| | | Address of Violation: |
|--|-------|-----------------------|
| CITY OF CHICAGO, a Municipal Corporation, Petitioner | ,) | 1461 W 114th Place |
| · · |) | |
| v. |) | |
| Niazi, Ayaz |) | Docket #: 15BT01065A |
| 1773 LINDEN PARK LN |) | |
| AURORA, IL 60504 |) | Issuing City |
| and |) | Department: Buildings |
| Niazi, Ayaz |) | |
| 4316 BAYHEAD CT, APT 2D |) | |
| AURORA, IL 6050/ |) | |
| , Responden | ts.) | |

FINDINGS, DECISIONS & ORDER

This matter coming for Hearing, notice given and the Administrative Body advised in the premises, having considered the motions, evidence and arguments present d. IT IS ORDERED: As to the count(s), this tribunal finds by a preponderance of the evidence and rules as follows:

Count(s) Municipal Code Violated

| <u> </u> | <u>inaing</u> | NOTE () | Count(S) | municipal Code Violated | renautes |
|----------|---|------------|----------|--|----------|
| | iable - By contested finding - Motion set-aside default granted | 15HS431824 | C | 132016 Heat dwelling unit adequately from September 15th to June 1st. (13-196-410) | \$500.00 |
| | | | 0, | 154027 Supply adequate hot water with minimum temperature of 120 days see F. (13-196-430) | \$500.00 |
| | | | 3 | 1970 19 Install and maintain approved smake detectors. (13-196-100 thru 13-190-160) Install a smoke detector in evaluating unit. Install one on any living level with a habitable room or unenclosed heating plant, on the uppermost ceiling of enclosed porch strarwell, and within 15 feet of every sleeping room. Be sure the detector is at least 4 inches from the wall, 4 to 12 | \$500.00 |

4 197087 Install carbon monoxide detector within 40 feet of every sleeping room in residential structure. (13-64-190, 13-64-210) A carbon monoxide detector is needed whenever there is a heating appliance on the premises that burns fossil fuel such as gas, oil, or coal, or air that is circulated through a heat exchanger. Install according to manufacturer instructions. A

inches from the ceiling, and not above door or window.

\$1,000.00

Pounities

Date Printed: Jul 20, 2015 9:46 am


15BT01065A

Page 1 of 2

DOAH - Order

UNOFFICIAL C

(1/00)



IN THE CITY OF CHICAGO, ILLINOIS DEPARTMENT OF ADMINISTRATIVE HEARINGS

Finding

NOV#

Liable - By contested finding - Motion 15HS431824 to set-aside default granted

Count(s) Municipal Code Violated

Penalties

hard wired model requires an electrical wiring permit. In a single family residence, be sure the detector is on or below the lowest floor with a place to sleep. In a multiple dwelling residence heated by a boiler, install a detector in the same room as the boiler. Otherwise, each apartment follows single family guidelines. The owner is responsible for installation and written instructions, the tenant for testing, maintenance, and batteries.

window frame to keep rain and wind out of dwelling. (13-196-550)

\$500.00 5 104075 Repair or replace defective

Sanction(s):

Admin Costs: \$60.00

Or Coop Co JUDGMENT TOTAL: \$3,060.00

Balance Due: \$3,060.00

Respondent is ordered to come into immediate compliance with any/all or as anding Code violations.

Prior default order(s) of Mar 30, 2015, is hereby vacated.

ENTERED:

Administrative Law Judge

May 7, 2015

Date

This Order may be appealed to the Circuit Court of Cook Co. (Daley Center 6th FL) within 35 days by filing a civil law suit and by paying the appropriate State mandated filing fees.

Pursuant to Municipal Code Chapter 1-19, the city's collection costs and attorney's fees shall be added to the balance due if the debt is not paid prior to being referred for collection.

15BT01065A

Page 2 of 2

Date Printed: Jul 20, 2015 9:46 am

1613001096 Page: 4 of 4

UNOFFICIAL COPY

LOT 7 IN BLOCK 44 IN ROGER'S RESUBDIVISION OF LOT / IN BLOCK 40 IN BLOCK 5 RESULTIVISHON OF INDICES 42 AND 43, LOTS 1 TO 16 IN BLOCK 44, LOTS 21 TO 26 IN BLOCK 54, BLOCK 60 (EXCEPT LOTS 1 TO 14 AND 49 BLOCK 60 (EXCEPT LOTS 1 TO 14 AND BLOCK 50, 81,82,83,84 AND 85 IN WASHINGTON HEIGHTS IN THE WEST HALF OF THE NORTHWEST QUARTER, OF SECTION 30, TOWNSHIP 57 NORTH, RANGE 14 EAST OF THE THURD PHINCIPAL MEMBIAN, ACCORDING TO A MAP OF SIAD ROGER'S SUBDIVISION RECORDED ON APRIL 14, 1173 AS DOCUMENT 9481, IN BOOK 4 OF PLATS PAGE 47, IN COOK COUNTY ILLINOIS

PDN: 25-20-127-000-0000

The Masson

Topologists of Collins Cloth's Office